



July 21<sup>st</sup>, 2021

To Whom It May Concern:

RE: 3377 Bobtail, Libby, MT

On July 21<sup>st</sup>, 2021 the septic at 3377 Bobtail, was pumped and inspected. The tank is a 1000 gallon concrete tank with filter and is in good working condition at the time of pumping. There are no visible cracks or signs of erosion around the tank but one of the concrete lids does need to be replaced, water levels in tank were good. There was no noted standing water on the property. Also, we recommend that the filter on the outlet side of the tank be cleaned annually.

Sincerely,

Amy Johnson, Owner  
JMF Services, INC